



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Scott Walker, Governor
Dave Ross, Secretary

August 16, 2011

DSPS
SAFETY AND BUILDINGS
JIM MILLER
201 W WASHINGTON AVE
MADISON WI 53701

Re: Description: POOL - INTERNAL POOL WALL FOR STEPS, ALTERNATE POOL SYSTEM
Manufacturer: DSPS
Product Name: INTERNAL POOL WALL FOR STEPS
Model Number(s): NONE
Product File No: 20110257

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 90.09 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The wall is a maximum of 18 inches in width.
- The wall extends into the pool no more than one foot beyond the termination of the steps.
- The wall includes a code compliant handrail on the step side of the wall.
- The wall is installed so as to be above the high water level in the pool.
- The top of the wall is constructed so as to be slip resistant.

This approval supersedes the approval issued on June 21, 2006 under product file number 20060297.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060297.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

James H. Miller
Section Chief, Bureau of Integrated Services
Phone: 608-266-8072
Fax: 608-267-9566
email: jim.miller@wi.gov